

4/2025.

DECLARATION OF PERFORMANCE

- Product specific identification code: **SIGNAL PS-128F external fire alarm siren**
- The purpose or purposes of the construction product determined by the manufacturer in accordance with the applicable harmonized technical regulation:
Outdoor fire alarm siren equipment
- Name and address of the manufacturer:
TRIÓDA Vagyondvédelmi Kft. (H-1191 Budapest, Ulloi út 206.)
- Authorized representative: Istvan Jakli, Technical Department Manager - jakli.istvan@trioda.hu
- AVCP system (system for evaluating and controlling the constancy of the performance of construction products):
System No. 1 (305/2011/EU regulation annex V. section 1.2.)
- In the case of a manufacturer's declaration for construction products regulated by harmonized standards:
EN 54-3:2001/A12002; EN 54-3:2001/A2:2006 Fire alarm equipment, part 3: Alarm units, sounders
Registered organization:
ÉMI Építészeti Minőségellenőrző Innovációs Nonprofit Kft. (H-2000 Szentendre, Dózsa György út 26.)
with member number NB 1415 performed in system (1) and published the
(EK-) Certificate of constancy number 1415-CPR-53-(C-53/2016) of the product.
- Performance according to the statement

Essential characteristic	Performance	EN 54-3:2014 standard clause
Performance in case of fire: sound pressure	120 dB(A)	4.2, 4.3, 5.2, 5.3
Operational reliability	appropriate	4.4, 4.5, 4.6, 5.4
Operational reliability: durability of heat resistance	appropriate -20...+60°C	5.5, 5.6, 5.7, 5.8, 5.9
Operational reliability: durability of humidity resistance	appropriate 0...93RH%	5.8, 5.9, 5.10
Operational reliability: durability of vibration	appropriate	5.12...5.15
Operational reliability: durability of electrical stability	appropriate EN 50130-4	5.16
Enclosure protection (IP-code) EN 60529:	IP33C (type A)	5.17

- Performance of the product mentioned in the 1st and 2nd points complies with the 7th point's statement.
The manufacturer mentioned in the 4th point is responsible for issuing this declaration of performance.
On behalf of the manufacturer: Istvan Jakli, Technical Department Manager

Budapest, 01/10/2025


Istvan Jakli, Technical Department Manager