

EC-CERTIFICATE OF CONSTANCY OF PERFORMANCE

1415-CPR-52-(C-53/2016)

ANNEX

SIGNAL PS 128F siren

Dimensions:	295 × 200 × 100 mm
Weight:	3,0 kg
IP protection:	IP 34
Power supply:	20...28 VDC
Battery (1pc):	12 V / 7 Ah
Minimum battery voltage:	10,8 V
Bulb power:	12 V / 18 W
Standby current consumption:	4 mA
Maximum battery charger current:	100 mA
Sounder alarm current consumption:	1,2 A
Maximum current consumption:	2,8 A
Sound pressure:	118 dB
Sounder frequency:	900...2400 Hz
Maximum siren time:	optional

Dated at Szentendre, on 21th October 2016



2/3

EC-CERTIFICATE OF CONSTANCY OF PERFORMANCE

1415-CPR-52-(C-53/2016)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

SIGNAL PS 128F siren

with product performance and fire safety intended use shown in the annex as page 3/3 of this certificate and

produced by

TRIÓDA Vagyonvédelmi Kft.

1191 Budapest, Üllői út 206.

and produced in the manufacturing plant

TRIÓDA Vagyonvédelmi Kft.

1191 Budapest, Üllői út 206.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006 under system (1) are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 21.10.2016. and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Dated at Szentendre, on 21th October 2016





Pataki Erika
Head of Certification Office
Certification Office
of ÉMI Non-profit Ltd.